



Product Service

CERTIFICATE

No. Z10 075157 0031 Rev. 00

Holder of Certificate: Pizzato Elettrica s.r.l.

Via Torino 1
36063 Marostica (VI)
ITALY

Certification Mark:



Product: Safety components
Model(s): Programmable Safety Controller
Gemnis CS M

Parameters: Ambient Temperature: 0°C ... +55°C
Response time: < 30 ms
(< 40 ms for relay output versions)
Operating voltage: 24 Vdc ±15%

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report PM88729C in the current valid revision.

Tested according to: EN ISO 13849-1:2015 (Cat.4, PL e)
EN 61508-1:2010 (SIL 3)
EN 61508-2:2010 (SIL 3)
EN 61508-3:2010 (SIL 3)
EN 62061:2005/A2:2015 (SIL CL3)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: PM88564T
Valid until: 2026-06-06

Date, 2021-06-08

(Peter Weiß)